



System schematic

Cascade Logatherm WLW286.2

Hydraulic components:


- Air-to-water heat pump (cascade)
- Buffer tank
- Hot water tank
- Heating/cooling circuits






Page 4

WPM100.2






- 1) Speed control optional
- 2) Additional equipment - only one card can be installed (LWPM410 or KNX WPM).
- 3) Alternative connection option for M16: to XM16 in the outdoor unit (voltage and speed control)

	0		I		II		III		
(1)	DI1	A1/K22	DI3	---	DI7	---	DI9	---	(1)
(2)	DI2	A2/K23	DI4	---	DI8	---	DI10	---	(2)
(3)	U1	R1	U7	R3	U9	---	U11	---	(3)
(4)	U2	R2.2	U8	---	U10	---	U12	---	(4)
(5)	NO1	M13	NO5	YM18	NO8	---	NO11	---	(5)
(6)	NO2	H5	NO6	M24	NO9	---	NO12	---	(6)
(7)	NO3	E10.1	NO7	E9	NO10	---	NO13	---	(7)
(8)	Y1	M13 ¹⁾	Y3	---	Y4	---	Y5	---	(8)
(9)	U3	N27.1	Warmwasser domestic hot water eau chaude sanitaire +A420						(9)
(10)	U4	N27.2							(10)
(11)	U5	---							(11)
(12)	U6	---							(12)
(13)	NO4	M16 ³⁾							(13)
(14)	Y2	M16 ³⁾							(14)

[illegible]


②



- 1) Speed control optional
- 2) Additional equipment - only one card can be installed (LWPM410 or KNX WPM).
- 3) Alternative connection option for M16: to XM16 in the outdoor unit (voltage and speed control)

	0		I		II		III		
(1)	DI1	A1/K22	DI3	---	DI7	---	DI9	---	(1)
(2)	DI2	A2/K23	DI4	---	DI8	---	DI10	---	(2)
(3)	U1	R1	U7	---	U9	---	U11	---	(3)
(4)	U2	R2.2	U8	---	U10	---	U12	---	(4)
(5)	NO1	M13	NO5	---	NO8	---	NO11	---	(5)
(6)	NO2	H5	NO6	---	NO9	---	NO12	---	(6)
(7)	NO3	E10.1	NO7	---	NO10	---	NO13	---	(7)
(8)	Y1	M13 ¹⁾	Y3	---	Y4	---	Y5	---	(8)
(9)	U3	N27.1							(9)
(10)	U4	N27.2							(10)
(11)	U5	---							(11)
(12)	U6	---							(12)
(13)	NO4	M16 ³⁾							(13)
(14)	Y2	M16 ³⁾							(14)

WPM100.2



- 1) Speed control optional
- 2) Additional equipment - only one card can be installed (LWPM410 or KNX WPM).
- 3) Alternative connection option for M16: to XM16 in the outdoor unit (voltage and speed control)

	I	II	III	IV
(1)	D1I A1/K22	DI3 ---	DI7 ---	DI9 ---
(2)	DI2 A2/K23	DI4 ---	DI8 ---	DI10 ---
(3)	U1 R1	U7 ---	U9 ---	U11 ---
(4)	U2 R2.2	U8 ---	U10 ---	U12 ---
(5)	NO1 M13	NO5 ---	NO8 ---	NO11 ---
(6)	NO2 H5	NO6 ---	NO9 ---	NO12 ---
(7)	NO3 E10.1	NO7 ---	NO10 ---	NO13 ---
(8)	Y1 M13 ¹⁾	Y3 ---	Y4 ---	Y5 ---
(9)	U3 N27.1			
(10)	U4 N27.2			
(11)	U5 ---			
(12)	U6 ---			
(13)	NO4 M16 ³⁾			
(14)	Y2 M16 ³⁾			

Technical notes

General information

- To cover larger heat demands, two heat pumps are cascaded.
- This configuration is suitable for applications with heating and cooling demand.
- In monoenergetic operation, the heat pump covers the heating and hot water demand.
- A general connection of pumps by means of a coupling relay is recommended.
- The components of the hydraulic system, such as DDV, PW... E and the pipelines, must be dimensioned according to the required outputs/volume flows.
- The correct size and connection of the buffer tank must be ensured. If necessary, a four-way connection or several buffer tanks connected in parallel should be provided.
- An additional heat source must be provided in the hydraulics to ensure the frost protection of the heat pump in all operating conditions.

Hot water preparation

- If thermal disinfection is required or desired, this can be done via an electric flange heater in the hot water tank. The electric flange heater is connected to the heat pump manager WPM100.2 via a relay K21 (terminal E9) and can be controlled there via a time program.
- In order to keep the share of the electric auxiliary heater as low as possible, the heat pump operates with priority.

Control

- The cascade control unit WPM100.2K as the higher-level master ensures that the operating times of the heat pumps are evenly distributed.
- With a heat pump cascade, only 1 outdoor temperature sensor R1 is required (installation on the master control unit WPM100.2K).
- In a heat pump cascade, 1 request temperature sensor R2.2 is required for each control unit (installation on the master control unit WPM100.2K and on the slave control units WPM100.2).

Cooling

- The relay K28 can be used externally as a signal for switching between heating and cooling.
- With silent cooling, the water temperature must always be kept above the dew point temperature. For this purpose, at least one room controller (RTM Econ) must be installed in a reference room in order to regulate the min. permissible flow temperature depending on the measured room temperature and humidity. To avoid condensation at critical points in the cooling system, up to 5 dew point sensors (TPF341) in conjunction with a dew point monitor (TPW WPM) can interrupt the cooling operation if necessary.
- With dynamic cooling, all pipes and the buffer tank must be provided with vapor diffusion-proof insulation. The heat pump is switched on and off via the set return temperature. The room temperature control must be taken over by the temperature controllers of the fan convectors.
- If cooling below the dew point is desired, a storage tank with vapor diffusion-proof insulation should also be selected (e.g. BTHC1000). Otherwise, only cooling above the dew point is possible and the system must be monitored by using dew point sensors (TPF314 - N5).

Technical notes

Buffer and hot water tanks that can be combined with the heat pump

■ Heat pump buffer tank matrix

Heat pump	Buffer tank (heating)			Buffer tank (heating/cooling)		
	PW200 E	PW500 ER	PW1000 E	BTHC1000	System buffer tank 500	System buffer tank 1000
4x WLW286.2-22	—	—	✓	✓	✓	✓
4x WLW286.2-42	—	—	✓	✓	—	✓

Table 1: Selection table for buffer tank

■ Heat pump hot water storage tank matrix

Heat pump	Hot water tank		
	SH400	SH500	SH700
WLW286.2-22	✓	✓	✓
WLW286.2-42	—	—	✓

Table 2: Heat pump-hot water tank matrix

Further notes

Legal notices

This circuit diagram is a non-binding schematic representation of a possible hydraulic circuit.

The dimensions and the position of the connections can be found in the respective installation instructions.

The electrical wiring is shown in detail in the circuit diagrams.

The safety devices must be designed in accordance with the currently valid standards and local regulations.

Legend

Symbol	Description	Symbol	Description	Symbol	Description	Symbol	Description	Symbol	Description
Regulators and modules position									
	1 at the heat/cooling generator				4 in the station or on the wall				
	2 at the heat/cooling generator or on the wall				5 on the wall (reference room)				
	3 in the station				6 in the control unit				
Piping/Electrical wiring									
	Flow - Heating/Solar		Flow Brine		Domestic hot water		Domestic cold water		Electrical wiring
	Return - Heating/Solar		Return Brine		Domestic hot water circulation		Refrigeration system		Electrical wiring with a break
Actuators/Valves/Temperature Sensors/Pumps									
	Ventil		Revisionsbypass		Balancing valve		Overflow valve		Shout-off valve with dirt trap (with or without magnet)
	Kappenventil		Shut-off valve with actuator		Shut-off valve with therm. thermostatic actuator or anti-freeze valve		Absperrventil, magnetically controlled		Differential pressure regulator
	3-way valve with actuator (mixing)		3-way valve with actuator (distributing)		3-way valve with thermostatic actuator		Pumpe		Check valve
	3-way valve with actuator (switching)		3-way valve with actuator (switching, adjustable)		4-way valve with actuator		Safety valve		Safety group
	Temperature sensor		Safety temperature limiter		Flue gas temperature sensor		Flue gas temperature limiter		Outdoor temperature sensor
Miscellaneous									
	Radio (e.g., Controller, Sensor)		Thermometer		Manometer		Drain funnel with odor trap		Filling/draining valve
	Relay		Automatic/manual air vent		Air separator		Dirt trap		Magnetite/Sludge separator
	Compensator		Domestic hot water outlet		Heat meter		Volumetric flow meter		Collection tank
	Low loss header with sensor		Heat exchanger		System separation according to EN1717		Expansion vessel with cape valve		Immersion heater
	Heating circuit		Underfloor heating circuit		Ventilation heating circuit		Swimming pool heating circuit		Circuit function (Heating/Cooling)